

**EU Declaration of Conformity**

issued under the sole responsibility of the manufacturer

The object of this declaration: Head-mounted smart temperature transmitter types:

<b>LI-24G</b>	MODEL ID: 0025 0010 XXXX XXXX XXXX 0000 0001 XX
<b>LI-24G</b>	MODEL ID: 0025 0010 XXXX XXXX XXXX 0001 0001 XX
<b>LI-24G Safety</b>	MODEL ID: 0004 0006 0003 XXXX XXXX XXXX 0001 XX

Manufacturer: **APLISENS S.A.,  
ul. Morelowa 7,  
03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Rail-mounted smart temperature transmitter type **LI-24G, LI-24G Safety** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.

The following standard were applied EN 61326-1:2013, EN 61326-2-3:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN 50581:2012.

Head-mounted smart temperature transmitter in Ex version types **LI-24G** MODEL ID: 0025 0010 XXXX XXXX XXXX 0001 0001 XX and **LI-24G Safety** MODEL ID: 0004 0006 0003 XXXX XXXX XXXX 0001 XX comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe versions of transmitters are marked with the following certificate marking:

I M1 Ex ia I Ma  
II 1G Ex ia IIC T5/T6 Ga  
II 1D Ex ia IIIC T105°C Da  
KDB 20 ATEX 0005X

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012, EN 50303:2000.

Conformity assessment procedure; module B. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Notification of quality assurance: Module D. Notified Body no,1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice,

Warsaw, 10.02.2020

Adam Żurawski  
General Manager