



Physical Technical Testing Institute
Ostrava – Radvanice



EC-Type Examination Certificate

- (1)
- (2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 94/9/EC)**
- (3) EC-Type Examination Certificate Number:
FTZÚ 12 ATEX 0193X
- (4) Equipment or protective system:
**Pressure transmitter PC-28, PCE-28, PC-28Ex Safety, PCE-28Ex Safety
Differential pressure transmitter PR-28, PRE-28, PR-28Ex Safety, PRE-28Ex Safety
Hydrostatic level probe PC-28P, PCE-28P**
- (5) Manufacturer: **APLISENS S.A.**
- (6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**
- (7) This equipment or protective system and any of acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) The Physical Technical Testing Institute, notified body number 1026 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
The examination and test results are recorded in confidential Report N°:
12/0193 dated 04.04.2013
- (9) Compliance with Essential Health and Safety Requirements has been assured by compliance with:
EN 60079-0:2009, EN 60079-11:2012, EN 60079-26:2007, EN 50303:2000
- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type Examination Certificate relates only to the design, examination and testing of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- (12) The marking of the equipment or protective system shall include the following:

 **I M1 Ex ia I Ma
II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb
II 1D Ex ia IIIC T110°C Da**

This EC-Type Examination Certificate is valid till: **04.04.2018**

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2013

Page: 1/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



**Physical Technical Testing Institute
Ostrava – Radvanice**

(13)

Schedule

(14) **EC-Type Examination Certificate N° FTZÚ 12 ATEX 0193X**

(15) Description of Equipment or Protective System:

The device is used as a pressure transmitter (PC*-28*), or differential pressure transmitter (PR*-28*), or hydrostatic level probe (PC*-28P). The device converts non electrical process variable, which is pressure, into electrical 4...20mA output signal.

- measurement head including pressure sensor (various types),
- fully encapsulated main PCB (additional small auxiliary PCBs might exist depending on version),
- steel cylindrical enclosure,
- cable connector (various types: with cable gland or fixed external cable).

Ambient temperature: $-40^{\circ}\text{C} \dots T_{\text{amb}_{\text{max}}}$

Pi [W]	T _{amb_{max}} [°C]	Temperature class, Group
0,7	+45	T6
	+80	T5, T4, Gr. I, Gr.III-110°C
1,2	+75	T5
	+80	T4, Gr. I, Gr.III-110°C

Intrinsic safe parameters

In case of power supply with linear output characteristic:

U_i=28VDC, I_i=0,1A, P_i=0,7W, C_i=25nF+cable capacitance*, L_i=0,4mH+cable inductivity*

In case of power supply with trapezoidal or rectangular output characteristic:

U_i=24VDC, I_i=0,1A, P_i=1,2W, C_i=25nF+cable capacitance*, L_i=0,4mH+cable inductivity*

* - concerns versions with PK(M) and SG(M) connectors; cable parameters C=200pF/m, L=1μH/m

(16) Report No.: 12/0193

(17) Special conditions for safe use:

1. Ambient temperature range – see Instruction manual and marking label.
2. Process temperature (medium) at the diaphragm of the transmitter must be in range of ambient temperature.
3. In case of use the transmitter in dust atmosphere, supplying voltage could occur on transmitter enclosure. It should be taken into consideration during transmitter installation.
4. In case of use titan parts in diaphragm seal, during installation and operation of the device the diaphragm seal should be protected against mechanical impact.
5. Version of the transmitter with surge arrester, marked on the plate "Version SA", does not meet the requirements of Section 6.3.13 of EN 60079-11:2012 (test of isolation 500VAC). This must be taken into account during the installation of transmitters.

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2013

Page: 2/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



Physical Technical Testing Institute
Ostrava – Radvanice

(13)

Schedule

(14) **EC-Type Examination Certificate N° FTZÚ 12 ATEX 0193X**

(18) Essential Health and Safety Requirements:

Essential health and safety requirement of Directive 94/9/EC are covered by the standard mentioned in (9), according which the product was verified and in the manufacturer's instruction for use.


(19) List of Documentation:

Number:	Date:	Title:	Pages:
1 PC28-A150-01	09.2012	Technical description + drawings	5
2 AN.PC-28.03	-	Intrinsic safety discussion + annexes	12
3 DTR.PC.PR-28.02	09.2012	User manual for PC-28, PR-28, PC-28P	29
4 DTR.PC.PR-28 Safety	09.2012	User manual for PC-28 Safety, PC-28Ex Safety, PR-28 Safety, PR-28Ex Safety	29
5 DTR.PCE.PRE-28.02	09.2012	User manual for PCE-28, PRE-28, PCE-28P	29
6 DTR.PCE.PRE-28 Safety	09.2012	User manual for PCE-28 Safety, PCE-28Ex Safety, PRE-28 Safety, PRE-28Ex Safety	29

Drawing list:

Number:	Date:	Pages:			
PC28-C151-TA	08.2012	3	PC29-B014-01	10.2009	1
PC28-C152-TA	08.2012	3	PC28-B017-01	08.2012	1
PC28-C153-TA	08.2012	3	PC28-B018-01	08.2012	1
PC28-C154-TA	08.2012	3	PC28-B019-01	08.2012	1
PC28-S151-TA	08.2012	1	ZG-002-TA	06.2007	1
PC28-S152-TA	08.2012	1	ZG-006-TA	10.2004	1
PC28-S153-TA	08.2012	1	EP-232-01	02.2011	1
PC28-B151-TA	08.2012	5	GC1-007-TA	01.2010	3
PC28-B152-TA	08.2012	6	GC3-001-TA	03.2011	3
ACP2000-B122-01	01.2012	2	GC3-003-TA	01.2010	2
PC28-A151-TA	08.2012	7	GC4-001-TA	05.2012	3
PR28-A152-TA	08.2012	5	GC4-005-TA	03.2011	3
PC28P-A153-TA	08.2012	8	GC4-019-TA	02.2012	3
PC28-A154-TA	07.2012	2	GR40-001-TA	09.2010	2
PR28-A155-TA	07.2012	2	GR40-003-TA	09.2009	1
PC29-B012-02	12.2010	1	GR50-001-TA	07.2010	2
PC29-B013-01	10.2009	1	GSP-002-TA	10.2008	2

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2013

Page: 3/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



(1) **Supplement No. 1 to
EC-Type Examination Certificate**

(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 94/9/EC)**

(3) EC-Type Examination Certificate Number:

FTZÚ 12 ATEX 0193X

(4) Equipment or protective system:

**Pressure transmitter PC-28, PCE-28, PC-28Ex Safety, PCE-28Ex Safety,
Differential pressure transmitter PR-28, PRE-28, PR-28Ex Safety, PRE-28Ex Safety,
Hydrostatic level probe PC-28P, PCE-28P**

(5) Manufacturer: **APLISENS S.A.**

(6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**

(7) This supplement of certificate is valid for: - application of new standards
- modification of certified apparatus

(8) Modification of certified apparatus (protective system) and any of its approved variants are specified in documentation, list of which is mentioned in schedule of this certificate.

(9) This supplement to type examination certificate is valid only for type examination of design and construction of product sample in accordance with Annex 3 Paragraph 6) of Directive No. 94/9/EC. The Directive contains another requirements, which manufacturer shall fulfill before products are place on market or introduce in service.

(10) Safety requirements of modified parts were fulfilled by satisfying the following standards:


EN 60079-0:2012/A11:2013, EN 60079-11:2012, EN 50303:2000

(11) Marking of equipment shall contain symbols:

 **I M1 Ex ia I Ma**
 **II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb**
 **II 1D Ex ia IIC T110°C Da**
 **II 1/2G Ex ia IIC T4 Ga/Gb** – (for transmitters with connection ALW)

(12) This type examination certificate is valid till **04.04.2018**

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 15.02.2016

Page: 1/3

This supplement to certificate is granted subject to the general conditions of the FTZÚ, s.p.
This supplement to certificate may only be reproduced in its entirety and without any change, schedule included.



Physical Technical Testing Institute
Ostrava – Radvanice

(13)

Schedule

(14)

Supplement No. 1 to
EC-Type Examination Certificate N° FTZÚ 12 ATEX 0193X

(15) Description of Equipment or Protective System:

Added versions of pressure transmitters and differential pressure transmitters with electrical connections type: PKD, PM12, ALW. Transmitters with electrical connection ALW are equipped with LCD display mounted on the plate AM1-rev2 enclosed in light alloy housing with PM12 or PD connector. Transmitters with electrical connection PKD, PM12 and ALW equipped with PM12 connector are allowed only to hazardous gas explosive atmospheres (Group II). Transmitters with ALW connection with connector PD are allowed for gas and dust hazardous explosive atmospheres (Group II and Group III).

Added the ability to use layer of PTFE thickness max. 0.15mm covering the wetted surfaces of pressure separators.

Added replacements of previously used: silicone sealant, power cable and electrical connector PD.

Introduced version of transmitter is allowed for hazardous explosive gas atmospheres with minimum ambient temperature $T_a \geq -50^\circ\text{C}$.

Introduced minor other changes do not affect the intrinsic safety.

Ambient temperature:

$T_a = -40^\circ\text{C}$ to $+80^\circ\text{C}$

$T_a = -50^\circ\text{C}$ to $+80^\circ\text{C}$ - version only for explosive gas atmospheres (Group II)

Other technical parameters, intrinsically safe parameters and construction of apparatus remain unchanged.

(16) Report No.: 12/0193/1

(17) Special conditions for safe use: added new condition

17.1 Ambient temperature range – see Instruction manual and marking label.

17.2 Process temperature (medium) at the diaphragm of the transmitter must be in range of ambient temperature.

17.3 In case of use the transmitter in dust atmosphere, supplying voltage could occur on transmitter enclosure. It should be taken into consideration during transmitter installation.

17.4 In case of use titan parts in diaphragm seal, during installation and operation of the device the diaphragm seal should be protected against mechanical impact.

17.5 Version of the transmitter with surge arrester, marked on the plate "Version SA", does not meet the requirements of Section 6.3.13 of EN 60079-11:2012 (test of isolation 500VAC). This must be taken into account during the installation of transmitters.

17.6 Transmitters with display, (with electrical connection ALW) for Group III, should be installed in a place and in a way that prevents electrostatic charging.

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 15.02.2016

Page: 2/3

This supplement to certificate is granted subject to the general conditions of the FTZÚ, s.p.
This supplement to certificate may only be reproduced in its entirety and without any change, schedule included.



Physical Technical Testing Institute
Ostrava – Radvanice

(13)

Schedule

(14)

Supplement No. 1 to
EC-Type Examination Certificate N° FTZÚ 12 ATEX 0193X


(18) Essential Health and Safety Requirements:

Essential health and safety requirements of Directive 94/9/EC are covered by the standards mentioned in clause (10) of this supplement according which the new model was verified and in the manufacturer's Instruction for Using.

(19) List of Documentation:

<i>Document/Drawings:</i>	<i>Type of sheet:</i>	<i>Date:</i>	<i>Nr. of pages:</i>
PC28-A150-00	1A, 2	04.2015	2
PC28-A150-01	1A+5A	04.2015	5
PC28-C151-TA	1A+3A	04.2015	3
PC28-C152-TA	1A+3A	04.2015	3
PC28-S152-TA	1A	04.2015	1
(CER.Ex)PC28-S154-02	1,2,3,4	12.2015	4
PC28-B152-TA	1A, 5A, 6A	04.2015	3
(CER.Ex)PC28-B154-02	1+7	12.2015	7
PC28-A151-TA	2A, 5A, 6A	04.2015	3
PR28-A152-TA	2A, 4A, 5A	04.2015	3
PC28P-A153-TA	2A, 5A, 7A, 8A	04.2015	4
(CER.Exi)PC28-A156-TA	1,2,3	04.2015	3
PC28-A154-TA	1A	04.2015	1
PR28-A155-TA	1	04.2015	1
(CER.Exi)PC28-B155-02	1A	11.2015	1
U1-AN.PC-28.03_ATEX_IECEX	1	04.2015	9
DTR.PC.PR-28.02		06.2015	36

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 15.02.2016

Page: 3/3

This supplement to certificate is granted subject to the general conditions of the FTZÚ, s.p.
This supplement to certificate may only be reproduced in its entirety and without any change, schedule included.



(1) **Supplementary EU - Type Examination Certificate No. 2**

(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 2014/34/EU)**

(3) EU - Type Examination Certificate number:

FTZÚ 12 ATEX 0193X

(4) Product: **Pressure transmitter PC-28, PCE-28, PC-28Ex Safety, PCE-28Ex Safety,
Differential pressure transmitter PR-28, PRE-28, PR-28Ex Safety, PRE-28Ex Safety,
Hydrostatic level probe PC-28P, PCE-28P**

(5) Manufacturer: **APLISENS S.A.**

(6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**

(7) This supplementary certificate extends EC - Type Examination Certificate No. FTZÚ 12 ATEX 0193X to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

(8) The Physical-Technical Testing Institute, Notified Body number 1026, in accordance with Articles 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26.02.2014, certifies that this product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

(9) In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20.04.2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20.04.2016.

(10) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:


EN 60079-0:2012+A11:2013, EN 60079-11:2012, EN 50303:2000

(11) The marking of the product shall include the following:

 **I M1 Ex ia I Ma**
 **II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb**
 **II 1D Ex ia IIIC T110°C Da**
 **II 1/2G Ex ia IIC T4 Ga/Gb** – (for transmitters with connection ALW, ALM)

(12) This certificate is valid till: **04.04.2023**

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2018

Page: 1/3



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13) **Schedule**

(14) **Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 12 ATEX 0193X**

(15) Description of the variation to the Product:

The subject of this supplementary certificate is:

- Modification of certified apparatus;
- Prolongation of certificate validity.

Added versions of pressure transmitters and differential pressure transmitters with electrical connections type ALM. Transmitters with electrical connection ALM are equipped with LCD display mounted on the plate AM1-rev2 enclosed in light alloy housing with PM12 or PD connector. Transmitters with electrical connection ALM equipped with PM12 connector are allowed only to hazardous gas explosive atmospheres (Group II). Transmitters with ALM connection with connector PD are allowed for gas and dust hazardous explosive atmospheres (Group II and Group III).

Products PC-28 or PCE-28 with diaphragm seals can be equipped with heat shrinkable sleeve.

Added the ability to use layer of PTFE thickness max. 0,15mm covering the surfaces of pressure separators.

Introduced other minor changes do not affect the intrinsic safety.

Other technical parameters, intrinsically safe parameters and construction of apparatus remain unchanged.

(16) Report Number.: 12/0193/2


(17) Specific Conditions of Use: Edited to those listed previously

17.6 Transmitters with display (with electrical connections ALW, ALM) and with diaphragm seals covered by PTFE, for Group III, should be installed in a place and in a way that prevents electrostatic charging.

(18) Essential Health and Safety Requirements:

Compliance with the Essential Health and Safety Requirements is covered by standards mentioned in clause (10) of this supplementary certificate

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2018

Page: 2/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute
Ostrava - Radvanice

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 12 ATEX 0193X**

(19) Drawings and Documents:

<i>Document/Drawings:</i>	<i>Type of sheet:</i>	<i>Date:</i>	<i>Nr. of pages:</i>
PC28-A150-00	1B, 2A	02.2018	2
PC28-A150-02	1	02.2018	1
PC28-A151-TA	3A, 4A, 5B, 6B	02.2018	4
(CER.Exi)PC28-A156-TA	1A, 2A, 3A, 4	02.2018	4
PC28-A154-TA	1B	02.2018	1
PR28-A155-TA	1B	02.2018	1
(CER.Exi)SG25-A061-TA	1A	02.2018	1
U2-AN.PC-28.03_ATEX	1, 2	02.2018	2
DTR.PC.PR-28.02	F	02.2018	37

Responsible person:

Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2018

Page: 3/3



(1) **Supplementary EU - Type Examination Certificate No. 3**

(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 2014/34/EU)**

(3) EU - Type Examination Certificate number:

FTZÚ 12 ATEX 0193X

(4) Product: **Pressure transmitter PC-28, PCE-28, PC-28Ex Safety, PCE-28Ex Safety,
Differential pressure transmitter PR-28, PRE-28, PR-28Ex Safety, PRE-28Ex Safety,
Hydrostatic level probe PC-28P, PCE-28P, SG(E)-25, SG(E)-25S, SG(E)-25C**

(5) Manufacturer: **APLISENS S.A.**

(6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**

(7) This supplementary certificate extends EC - Type Examination Certificate No. FTZÚ 12 ATEX 0193X to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

(8) The Physical-Technical Testing Institute, Notified Body number 1026, in accordance with Articles 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26.02.2014, certifies that this product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

(9) In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20.04.2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20.04.2016.

(10) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018; EN 60079-11:2012; EN 50303:2000

If the sign "X" is placed after the certificate number, it indicates that the product is subject to Specific Conditions of Use specified in the schedule to this certificate.

(11) The marking of the product shall include the following:

Detailed description in section (15) – Description of the variation to the Product

(12) This certificate is valid till: **30.04.2028**

Responsible person:

Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 1/6

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13) **Schedule**

(14) **Supplementary EU - Type Examination Certificate No. 3
to FTZÚ 12 ATEX 0193X**

(15) Description of the variation to the Product:

The subject of this supplementary certificate is:

- Modification of certified apparatus;
- Added new types Hydrostatic level probe SG(E)-25, SG(E)-25S, SG(E)-25C
- Modification of product marking
- Evaluation according to the newest standards;
- Extension of certificate validity.


This supplementary certificate describes these changes of product

- Downsize of PCB PC30Ex-rev2;
- Marking, see below;
- Added the new documentation to the new PCB PC-30-rev7, changed the parameters Li and Ci, Ci = 2,5 nF + capacity of cable, Li = 0 mH + inductivity of cable;
- Added the ability to use layer of PTFE thickness max. 0,35mm covering the surfaces of diaphragm seals. Added warning table.
- Reduction the number of versions of the PC-28 transmitters with PM12, PKD, ALW, ALM connections;
- Changed seals in the cable connection SG;
- Updated drawings of transmitters, changed and added marking tables;
- Added new probes Hydrostatic level probe SG(E)-25, SG(E)-25S, SG(E)-25C with documentation;
- Updated implementation of pressure heads and differential pressure heads;
- Added new pressure heads and differential pressure heads;
- Updated and added new technical description;
- Updated list of documentation.

Hydrostatic level probe SG(E)-25, SG(E)-25S, SG(E)-25C

The hydrostatic level are installed in places where the liquid level is measured in wells, tanks, boreholes, etc. The probe is immersed in the measured medium.

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 2/6



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13) **Schedule**

(14) **Supplementary EU - Type Examination Certificate No. 3
to FTZÚ 12 ATEX 0193X**

(15) Description of the variation to the Product (continued):

Transmitters Px-28...

- | | | |
|--|---|--|
| | I M1 Ex ia I Ma | products with connection PD, PK, PKM, PZ, SG, SGM |
| | II 1/2G Ex ia IIC T6/T5/T4 Ga/Gb | products with connection PD, PK, PKM, PZ, SG, SGM, PM12, PKD |
| | II 1/2G Ex ia IIC T4 Ga/Gb | products with ALW, ALM with connection PD or PM12 |
| | II 1D Ex ia IIC T135°C Da | products with connection PD, PK, PKM, PZ, SG, SGM, ALW, ALM with connection PD |

Probes SG(E)-25x

- | | | |
|--|------------------------------------|--|
| | I M1 Ex ia I Ma | all SG... types |
| | II 1G Ex ia IIC T6/T5/T4 Ga | products without plastic tip and plastic cover |
| | II 1G Ex ia IIB T6/T5/T4 Ga | products with cable with protection ETFE or with additional protection by PTFE with metal wire |
| | II 2G Ex ia IIC T6/T5/T4 Gb | products with cable with additional protection by PTFE without metal wire |

Intrinsically safe parameters

Transmitters Px-28

Ambient temperature: $-40^{\circ}\text{C} < T_a < T_{\text{amax}}$ (special version for Group II only $T_{\text{amin}} = -50^{\circ}\text{C}$)

Power supply	Pi [W]	T _{amax} [°C]	Temperature class, Group	Surface temperature
Linear output characteristic: U _i = 28 VDC, I _i = 0.1 A	0.7	+45 °C	T6	85 °C
		+70 °C	T5	110 °C
		+80 °C	T4, Group I, Group III	120 °C
Rectangular or Trapezoidal output characteristic: U _i = 24 VDC, I _i = 0.1 A	1.2	+55 °C	T5	110 °C
		+80 °C	T4, Group I, Group III	135 °C

Input parameters:

Ver A: C_i = 25 nF + cable capacitance*, L_i = 0,4 mH + cable inductivity*

Ver B: C_i = 2.5 nF + cable capacitance*, L_i = 0 mH + cable inductivity*

* - concerns versions with PK(M), PKD and SG(M) connectors; cable parameters C = 200 pF/m, L = 1 μH/m

Responsible person:

Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 3/6

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute
Ostrava - Radvanice

(13) **Schedule**

(14) **Supplementary EU - Type Examination Certificate No. 3
to FTZÚ 12 ATEX 0193X**

(15) Description of the variation to the Product (continued):

Probes SG(E)-25x

Ambient temperature: $-25^{\circ}\text{C} < T_a < T_{\text{amax}}$

Power supply	Pi [W]	T _{amax} [°C]	Temperature class, Group
Linear output characteristic: U _i = 28 VDC, I _i = 0.1 A	0.7	+45 °C	T6
		+70 °C	T5
		+80 °C	T4, Group I
Rectangular or Trapezoidal output characteristic: U _i = 24 VDC, I _i = 0.1 A	1.2	+55 °C	T5
		+80 °C	T4, Group I

Input parameters:

C_i = 2.5 nF + cable capacitance*, L_i = 0 mH + cable inductivity*

* - cable parameters C = 200 pF/m, L = 1 μH/m

(16) Report Number: 12/0193/3

(17) Specific Conditions of Use:

1. Ambient temperature range – see Instruction manual and marking label.
2. Process temperature (medium) at the diaphragm of the transmitter or probe must be in range of ambient temperature.
3. In case of use the transmitter in dust atmosphere, supplying voltage could occur on transmitter enclosure. It should be taken into consideration during transmitter installation.
4. In case of use titan parts in diaphragm seal, during installation and operation of the device the diaphragm seal should be protected against mechanical impact.
5. Version of the transmitter or probe with surge arrester, marked on the plate "Version SA", does not meet the requirements of Section 6.3.13 of EN 60079-11 (test of isolation 500V rms). This must be taken into account during the installation of transmitters.
6. Transmitters with display (with electrical connections ALW, ALM) and with diaphragm seals covered by PTFE, for Group III, should be installed in a place and in a way that prevents electrostatic charging.
7. In hazardous areas, transmitters with diaphragm seals covered with a PTFE layer should be installed in places and in a manner preventing electrostatic charging.

Responsible person:

Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 4/6

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute
Ostrava - Radvanice

(13) **Schedule**

(14) **Supplementary EU - Type Examination Certificate No. 3
to FTZÚ 12 ATEX 0193X**

(18) Essential Health and Safety Requirements:

Compliance with the Essential Health and Safety Requirements is covered by standards mentioned in clause (10) of this supplementary certificate.

(19) Drawings and Documents:

Number	Issue	Revision	Sheets	Date	Description
U3-AN.PC-28.03.ATEX_iECEX	03		8	04.2022	ATEX analysis
AN.SG-25.ATEX_iECEX	01		9	04.2022	ATEX analysis
EN.IO.PCE.PRE.28	003	01	27	01.2023	User Manual
EN.IO.SGE	003	01	17	01.2023	User Manual
DTR.PCE.PRE-28 Safety (ENG)	B1		30	03.2023	User Manual
PC28-A150-00	--	--	1C, 2B	04.2022	List of construction drawings.
PC28-A150-01	--	--	1B,2B,3B,4B,5B	05.2022	Transmitters. Technical description.
SG25-A000-04	--	--	1B, 2B	04.2022	Hydrostatic depth probes. Technical description
PC28-C151-TA	--	--	1B, 2B, 3A	04.2022	Rating plate
PC28-C152-TA	--	--	1B, 2B, 3A	04.2022	Rating plate
SG25-C004-TA	--	--	1C, 2A	04.2022	Rating plate
PC28-C157-TA	--	--	1	04.2022	Warning plate
PC28-S126-TA	--	--	1	04.2022	Electrical diagram of the PC30-rev7 board assembly
PC28-B152-TA	--	--	1B	04.2022	PC30Ex-rev2 board assembly
PC28-B126-TA	--	--	1, 2, 3, 4	04.2022	PC30-rev7 board assembly
PC28-A151-TA	--	--	1B, 2B, 3B, 4B, 5C, 6C	04.2022	Pressure transmitter PC-28, PCE-28, PC-28Ex SAFETY, PCE-28Ex SAFETY
PR28-A152-TA	--	--	1B, 2B, 3A, 4B, 5B	04.2022	Differential pressure transmitter PR-28, PRE-28, PR-28Ex SAFETY, PRE-28Ex SAFETY

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 5/6

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute
Ostrava - Radvanice

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 3
to FTZÚ 12 ATEX 0193X**

(19) Drawings and Documents (continued):

Number	Issue	Revision	Sheets	Date	Description
PC28P-A153-TA	--	--	1B, 2B, 3A, 4B, 5B	04.2022	PC-28P, PCE-28P hydrostatic level probe
(CER.Exi) PC28-A156-TA	--	--	1B, 2B, 3B, 4A, 5	04.2022	PC-28 series transmitters with PM12, PKD, ALW, ALM electrical connections
PC28-A154-TA	--	--	1C	04.2022	PC-28, PCE-28 pressure transmitters with separators
PR28-A155-TA	--	--	1C	04.2022	Differential pressure transmitters PR-28, PRE-28 with separators
SG25-A051-TA	--	--	1A, 2A	04.2022	Depth probes SG-25, SG-25S, SG-25C, SGE-25, SGE-25S, SGE-25C
ZA-002-TA	--	--	1C, 2	04.2022 12.2015	Cable assembly
(CER.Ex) SG25-A061-TA	--	--	1C	04.2022	Cable connection SG (Cable seals in the gland)
GC3-001-TA	--	--	1D, 2D, 3D	01.2019	Head, low, medium and absolute pressure.
GC3-003-TA	--	--	1B, 2B	01.2019	Head with front diaphragm
GC4-001-TA	--	--	1D, 2D, 3D	01.2019	Medium, high, absolute pressure head.
GC4-005-TA	--	--	1D, 2D, 3D	07.2017	High pressure head
GR40-108-TA	--	--	1E, 2E, 3E, 4E	01.2019	Differential pressure head in welded version
GR40-109-TA	--	--	1B, 2B, 3B, 4B	02.2019	Ultrastable differential pressure head
GR40-003-TA	--	--	1F, 2F	02.2014	Differential pressure head with covers
GR50-102-TA	--	--	1, 2	09.2021	Differential pressure head without mech. overload
GC3-006-TA	--	--	1D, 2D	07.2022	Probe head SG25, SG25S, SG25C
GC3-018-TA	--	--	1A, 2A	08.2022	Depth probe head
GC4-006-TA	--	--	1, 2	08.2011	Probe head SG25, SG25S, SG25C

Responsible person:

Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 04.04.2023

Page: 6/6