

**EU Declaration of Conformity**

issued under the sole responsibility of the manufacturer

The object of this declaration, pressure device:

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX,Differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX.Manufacturer: **APLISENS S.A., ul. Morelowa 7, 03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX in all versions comply with directive:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A. The following standard was applied EN 61326-1:2013, EN 61326-2-3:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council. The following standard was applied: EN 50581:2012.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX in **PED** version comply with directive:

- **PED – 2014/68/EU** dated 15 May 2014

Transmitters in PED version acc. to module A, have specified on the nameplate parameters PS&gt;200bar, PT..., TS...

The following standards were applied: EN 13445-3:2014, EN ISO 14732:2013, WUDT-UC/2003.

Transmitters without specified parameters values PS, PT, TS were manufactured on the basis of article 4 p.3 Directive 2014/68/UE in accordance with the sound engineering practice. In this case, PED Directive doesn't require CE marking, however transmitter is marked CE due to requirement of other regulations of EU harmonization legislation.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX in Ex versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe versions of transmitters are marked with the following certificate marking:

I M1 Ex ia I Ma (version with ss316 housing)

II 1/2G Ex ia IIC T5/T4 Ga/Gb

II 1D Ex ia IIIC T105°C Da

KDB 19 ATEX 0011X

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-11:2012, EN 50303:2000.

Conformity assessment procedure: module B. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX, in explosion-proof versions are marked with the following certificate marking:

I M2 Ex db ia I Mb (version with ss316 housing)

II 1/2G Ex ia / db IIC T6/T5 Ga/Gb

II 1/2D Ex ia / tb IIIC T105°C Da/Db

KDB 19 ATEX 0011X

I M2 Ex db ia I Mb (version with ss316 housing)

II 2G Ex ia / db IIC T6/T5 Gb

II 2D Ex ia / tb IIIC T105°C Db

KDB 19 ATEX 0011X

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-1:2014, EN 60079-11:2012, EN 60079-26:2015, EN 60079-31:2014.

Conformity assessment procedure: module B. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Notification of quality assurance: module D. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 02.01.2020

Adam Żurawski  
General Manager