

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration is temperature device: **APT-2000ALW in MID version.**Manufacturer: **APLISENS S.A.,
ul. Morelowa 7, 03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above complies with relevant Union harmonization legislation.

Temperature transmitters type **APT-2000ALW** in MID version comply with directives/standards:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.
The following standard was applied: EN 12405-1:2018.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and the Council.
The following standard was applied: EN IEC 63000:2018.

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe Exi versions of temperature transmitters are marked with the following certificate marking:II 1/2G Ex ia IIC T4/T5 Ga/Gb
FTZU 09 ATEX 0155X

Conformity assessment procedure: module B. Notified Body no.1026, Physical Technical Testing Institute, Pikarska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012.

Temperature transmitters **APT-2000ALW** in **explosion-proof Exd** versions are marked with the following certificate marking:II 1/2G Ex ia/d IIC T* Ga/Gb
KDB 10 ATEX 122X

Conformity assessment procedure: module B. NB no.1453, Central Mining Institute - National Research Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-11:2012,
EN 60079-26:2015.

Notification of quality assurance: Module D. Notified Body no.1453, Central Mining Institute - National Research Institute, Plac Gwarków 1, 40-166 Katowice.

- **EN 12405-1:2018 Annex D, Temperature transducers**

Harmonized to the **MID Directive: 2014/32/UE, MI-002**

Temperature transmitters are marked with the above-named standards and parts certificate numer issued by Oil and Gas Institute – National Research Institute, Lubicz 25A, Kraków.

Warsaw, 12.11.2024

Jan Wąsowski
Proxy of the Management Board