

No EN.DZ.SGE.25.Modbus.U5

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration: smart hydrostatic level probes **SGE-25.Modbus**, **SGE-25S.Modbus** and **SGE-25C.Modbus**

Manufacturer: **APLISENS S.A.**,
ul. Morelowa 7,
03-192 Warszawa

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Smart hydrostatic level probes **SGE-25.Modbus**, **SGE-25S.Modbus**, **SGE-25C. Modbus** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.

The following standards were applied: EN 61326-1:2013, EN 61326-2-3:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN IEC 63000:2018.

Smart hydrostatic level probes types **SGE-25.Modbus**, **SGE-25S.Modbus**, **SGE-25C.Modbus** in Exi version comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Exi versions of probes are marked with the following certificate marking:

I M1 Ex ia I Ma
II 1G Ex ia IIB T4/T5/T6 Ga
FTZU 18 ATEX 0077X

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012, EN 50303:2000.

Conformity assessment procedure: module B. NB no.1026, Physical Technical Institute, Pikartská 1337/7, 716 07 Ostrava Radvanice.

Notification of quality assurance: module D. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 01.07.2021



Adam Żurawski
General Manager